

Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

Company Name	Zhejiang Ruihua Machinery Co., Ltd	Client ID	102557
Company Other Name		Type of Certification	Product Certification; System 5
Certification Standard	AS/NZS 1841.2-2007 : Portable fire extinguishers - Specific requirements for water type extinguishers		
Scheme	Global-Mark Product Conformance Scheme		
Certification Review Date	16/07/2024	Certification Expiry Date	10/09/2029
Certificate Issue Date	9/05/2015	Certificate Last Update Date	16/09/2024

APPROVED COMPANY/SITE ADDRESS(ES):

Western Industrial Zone, Lingshan Town Yuyao Zhejiang 315460 China

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jasanz.org/register for verification.



Certification Manager



Unique Certificate Code: 72948F1CE9571A15CC258B99000B30ED

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER

Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:
In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).

Model Identification	Model Name	Brand Name	Product Description / Attributes	Date Approved
SW90	9.0 L Water type extinguisher	Presto	9.0 L water type, Rating: 4A, FERN: 2557.02-103	25-Mar-24
SW90	9.0 L Water type extinguisher	FireWorld	9.0 L water type, Rating: 4A, FERN: 2557.02-203	25-Mar-24
SW90	9.0 L Water type extinguisher	No name	9.0 L water type, Rating: 4A, FERN: 2557.02-303	25-Mar-24
WW90	9.0 L Water type extinguisher	Presto	9.0 L water type, Rating: 4A, FERN: 2557.02-102	25-Feb-16
WW90	9.0 L Water type extinguisher	FireWorld	9.0 L water type, Rating: 4A, FERN: 2557.02-202	25-Feb-16
WW90	9.0 L Water type extinguisher	No name	9.0 L water type, Rating: 4A, FERN: 2557.02-302	25-Feb-16

Comments:

Extinguisher construction complies with AS/NZS 1841.1 standard requirements.

End of the document



Certification Manager

